

SAS Superstructure

Location: 04-SF-80-13.2 / 13.9 Client Name: CalTrans **Run date** 21-Nov-14 **Time** 7:13 PM

04-0120F4

04-SF-80-13.2/13.9

Self-Anchored

Suspension Bridge

Daily Diary Report by Bid Item

Contract No.: 04-0120F4

Diary #: 189 Const Calendar Day: 225 Date: 15-Jan-2013 Tuesday Inspector Name: Feather, Bernard Title: Transportation Engineer

Inspection Type: Intermittent

Shift Hours: 08:00 am 05:00 pm Break: 01:00 Over Time:

Federal ID: Location:

Reviewer: Shedd, Bill Approved Date: 20-Nov-14 Status: Approved

Weather			
Temperature 7 AM	12 PM	4PM	
Precipitation		Condition cold, clear AM; clear, warmer PM	
Working Day ✓ If no, explain:		Condition (1977)	
			Dispute
Diary:			Diopato
General Comments			
		ntractor coordination meeting 1000-1100. Process 203 response. Track progress of FWS field work. Misc	
04-0120F4 Bid Item: 067	C-COA-SCE.067	Seal & Caulk Cable Bands - East of W2	
AMERICAN BRIDGE/FLUOR, A JV			
Diary:			Dispute
Cable Band Caulking	067 C-CO	A-SCE.067	
No cable band caulking was c	onducted today bed	ause the ambiant temperature was below 40 degrees F.	
04-0120F4 Bid Item: 127	0-000-000.127	COMPRESS AIR (3 NPS) (T1 TOWER)	
F.W. SPENCER AND SON, INC			
Labor			
	Name	RT Hrs OT Hrs DT Hrs Total Remarks	Dispute
Contractor: F.W. SPENCER AND SC	,	400 000 000 400	
	DAMIAN LLANOS DAVID LAW	1.00	
Plumber/Pipefitter JNM	DAVID LAVV	1.00 0.00 0.00 1.00	
Diary:			Dispute
Tower Piping	127 0-000	-000.127	
After completing the installation of the tower head utilites, the FWS crew spent 1 hour installing the PS-25 spring loaded pipe supports.			
CCO-187 Bid Item: 001	0-MSI-EFA.187	MEP/Structural Interferences	
F.W. SPENCER AND SON, INC	O MOI EI ALIO	man, other detailed in the first of the firs	
Labor Trade Class	Name	RT Hrs OT Hrs DT Hrs Total Remarks	Dispute
Contractor: F.W. SPENCER AND SC			
Welder JNM	DAMIAN LLANOS	7.00 0.00 0.00 7.00	
Plumber/Pipefitter JNM	DAVID LAW	7.00 0.00 0.00 7.00	
Diary:			Dispute

Daily Diary Report by Bid Item Job Name: 04-0120F4 Inspector Name: Feather, Bernard Diary #: 189 Date: 15-Jan-2013 Tuesday CCO 187 Extra Work at Force 001 0-MSI-EFA.187 Account The FWS crew spent 7 hours finishing the installation of the utility outlets at elevation 158M per the directions given in the response to RFI 3056.

